

Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results							
			Cold water					Hot water		
			Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)	Coliform bacteria (mpn/100ml)	Escherichia coli (mpn/100ml)	Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)
W22	G020	04, 11 & 18/08/2025	0.25	7.69	< 0.07	0	0	0.22	7.87	< 0.07
	1020		0.20	7.18	< 0.07	0	0	0.25	7.88	< 0.07
	1061		0.44	7.30	< 0.07	0	0	0.11	8.04	< 0.07
	2025		0.31	7.37	< 0.07	0	0	0.11	8.24	< 0.07
	2066		0.20	7.55	< 0.07	0	0	0.12	8.16	< 0.07
	3025		0.28	7.50	< 0.07	0	0	0.13	7.83	< 0.07
	3066		0.25	7.49	< 0.07	0	0	0.13	8.07	< 0.07
	4001		0.12	7.22	< 0.07	0	0	0.16	7.72	0.32
	4026		0.45	7.27	< 0.07	0	0	0.11	7.71	< 0.07
	4067		0.11	7.26	0.14	0	0	0.21	7.79	< 0.07
	5001		0.24	7.38	< 0.07	0	0	0.16	7.72	< 0.07
	5024		0.12	7.51	< 0.07	0	0	0.14	7.66	< 0.07
	5066		0.12	7.53	< 0.07	0	0	0.29	7.70	0.13
	6001		0.31	7.12	< 0.07	0	0	0.27	7.70	< 0.07
	6023		0.14	7.50	< 0.07	0	0	0.10	7.77	< 0.07
	6055		0.31	7.19	< 0.07	0	0	0.15	8.10	< 0.07
	7001		0.12	7.59	< 0.07	0	0	0.13	8.10	< 0.07
	7039		0.17	7.57	< 0.07	0	0	0.20	7.94	< 0.07
8016	0.26	7.56	< 0.07	0	0	0.14	7.83	< 0.07		
W23	G023	11/08/2025	0.13	7.68	0.07	0	0	0.29	7.80	< 0.07
	1031		0.17	7.60	< 0.07	0	0	0.14	7.62	< 0.07
	1052		0.16	7.53	0.15	0	0	0.14	7.50	< 0.07
	2031		0.12	7.43	< 0.07	0	0	0.18	7.59	< 0.07
	2056		0.19	7.29	0.21	0	0	0.25	7.63	0.30
	3031		0.32	7.19	0.21	0	0	0.29	7.65	0.28
	3056		0.14	7.21	0.21	0	0	0.18	7.70	0.22
	4031		0.08	7.32	0.27	0	0	0.12	7.69	0.16
	4056		0.20	7.35	0.15	0	0	0.14	7.69	0.25

Reference standard: Instruções sobre escolha e instalação de dispensadores de água por ligação directa, Environmental Protection Bureau, Government of Macao, S.A.R.

Turbidity: ≤ 0.5 NTU; pH value: 6.00 - 8.50; Traceable metal of Lead: ≤ 0.01 mg/L (10 μ g/L); Coliform bacteria: Not detected; Escherichia coli: Not detected

Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results							
			Cold water					Hot water		
			Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)	Coliform bacteria (mpn/100ml)	Escherichia coli (mpn/100ml)	Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)
W32	G015	25/08/2025	0.10	7.64	0.07	0	0	0.16	7.40	0.18
	1023		0.21	7.45	< 0.07	0	0	0.26	7.32	0.23
	1053		0.10	7.60	< 0.07	0	0	0.14	7.55	0.07
	2023		0.19	7.38	< 0.07	0	0	0.13	7.64	< 0.07
	2053		0.14	7.34	< 0.07	0	0	0.12	7.55	< 0.07
	3023		0.11	7.33	< 0.07	0	0	0.10	7.69	0.09
	3053		0.12	7.36	< 0.07	0	0	0.12	7.62	0.17
	4023		0.08	7.44	< 0.07	0	0	0.11	7.79	0.31
	4053		0.12	7.38	< 0.07	0	0	0.09	7.78	0.32
	5023		0.13	7.32	< 0.07	0	0	0.08	7.81	0.12
	5053		0.10	7.40	< 0.07	0	0	0.20	7.64	< 0.07
	6023		0.15	7.48	< 0.07	0	0	0.17	7.72	0.25
	6053		0.16	7.27	< 0.07	0	0	0.13	7.55	0.29
	7013		0.09	7.37	0.10	0	0	0.15	7.76	0.33

Reference standard: Instruções sobre escolha e instalação de dispensadores de água por ligação directa, Environmental Protection Bureau, Government of Macao, S.A.R.

Turbidity: ≤ 0.5 NTU; pH value: 6.00 - 8.50; Traceable metal of Lead: ≤ 0.01 mg/L (10 μ g/L); Coliform bacteria: Not detected; Escherichia coli: Not detected

Water Quality Test Result of Edible Ice				
Location	Sampling Date	Results		
		Aerobic colony count (cfu/ml)	Coliform bacteria (mpn/100ml)	<i>Escherichia coli</i> (mpn/100ml)
Cotti Coffee (S8) (Loose ice)	04/08/2025	0	0	0
Seastea (S8) (Loose ice)		0	0	0
Reference standard: Microbiological Guidelines for Ready-to-eat Food, Department of Food Safety, Municipal Affairs Bureau, Government of Macao, S.A.R.				
Packaged ice: Aerobic colony count: <500 cfu/ml; Coliform bacteria: Not detected in 100ml; Escherichia coli: Not detected in 100ml				
Loose ice: Aerobic colony count: <1,000 cfu/ml; Coliform bacteria: <100 cfu/100ml; Escherichia coli: Not detected in 100ml				