

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results							
			Cold water				Hot water			
			Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)	Coliform bacteria	<i>Escherichia coli</i> (mpn/100ml)	Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)
W12	G037	03/03/2026	0.29	8.08	< 0.07	0	0	0.14	7.94	< 0.07
	1019		0.13	7.94	< 0.07	0	0	0.14	8.00	< 0.07
	1038		0.17	7.89	< 0.07	0	0	0.15	7.97	< 0.07
	2022		0.15	7.83	< 0.07	0	0	0.12	7.96	< 0.07
	2041		0.23	7.84	< 0.07	0	0	0.13	7.95	< 0.07
	3022		0.10	7.82	< 0.07	0	0	0.13	7.95	< 0.07
	3041		0.17	7.85	< 0.07	0	0	0.11	7.23	< 0.07
	4022		0.14	7.84	< 0.07	0	0	0.14	7.60	< 0.07
	4041		0.14	7.81	< 0.07	0	0	0.14	7.64	< 0.07
	5022		0.15	7.80	< 0.07	0	0	0.16	7.66	< 0.07
	5036		0.24	7.82	< 0.07	0	0	0.12	7.71	< 0.07
	6018		0.11	7.79	< 0.07	0	0	0.11	7.73	< 0.07
	6032		0.11	7.57	< 0.07	0	0	0.10	7.73	< 0.07
	7003		0.13	7.93	< 0.07	0	0	0.12	7.77	< 0.07
	7040		0.10	7.90	< 0.07	0	0	0.13	7.77	< 0.07
	8022		0.08	7.90	< 0.07	0	0	0.13	7.76	< 0.07
	8036		0.10	7.92	< 0.07	0	0	0.10	7.86	< 0.07
9003	0.12	7.96	< 0.07	0	0	0.11	7.92	< 0.07		
W21	G019	09 & 16/03/2026	0.10	7.56	< 0.07	0	0	0.15	7.66	< 0.07
	1020		0.11	7.58	< 0.07	0	0	0.09	7.65	< 0.07
	1061		0.37	7.58	< 0.07	0	0	0.08	7.72	< 0.07
	2025		0.10	7.58	< 0.07	0	0	0.10	7.72	< 0.07
	2066		0.14	7.63	< 0.07	0	0	0.08	7.76	< 0.07
	3001		0.08	7.66	< 0.07	0	0	0.08	7.76	< 0.07
	3024		0.10	7.64	< 0.07	0	0	0.08	7.72	< 0.07
	3066		0.15	7.85	< 0.07	0	0	0.13	7.79	< 0.07
	4001		0.10	7.58	< 0.07	0	0	0.10	7.68	< 0.07
	4024		0.11	7.64	< 0.07	0	0	0.09	7.74	< 0.07
	4066		0.08	7.63	< 0.07	0	0	0.08	7.74	< 0.07
	5001		0.08	7.66	< 0.07	0	0	0.08	7.70	< 0.07
	5024		0.09	7.77	< 0.07	0	0	0.07	7.78	< 0.07
	5065		0.07	7.51	< 0.07	0	0	0.10	7.78	< 0.07
	6001		0.09	7.59	< 0.07	0	0	0.11	7.72	< 0.07
	6033		0.10	7.63	< 0.07	0	0	0.08	7.77	< 0.07
	7001		0.08	7.61	< 0.07	0	0	0.08	7.70	< 0.07
7033	0.09	7.64	< 0.07	0	0	0.07	7.75	< 0.07		
8017	0.07	7.60	< 0.07	0	0	0.08	7.70	< 0.07		
9016	0.09	7.57	< 0.07	0	0	0.08	7.66	< 0.07		

Referência standard: Instruções sobre escolha e instalação de dispensadores de água por ligação directa, Environmental Protection Bureau, Government of Macao, S.A.R.

Turbidity: ≤ 0.5NTU; pH value: 6.00 - 8.50; Traceable metal of Lead: ≤ 0.01mg/L (10µg/L); Coliform bacteria: Not detected; *Escherichia coli*: Not detected

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results							
			Cold water					Hot water		
			Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)	Coliform bacteria	<i>Escherichia coli</i> (mpn/100ml)	Turbidity (NTU)	pH value	Traceable metal of Lead (µg/L)
W22	G020	16 & 30/03/2026	0.13	7.26	< 0.07	0	0	0.21	7.84	< 0.07
	1020		0.11	7.39	< 0.07	0	0	0.14	7.86	< 0.07
	1061		0.19	7.37	< 0.07	0	0	0.15	7.87	< 0.07
	2025		0.18	7.41	< 0.07	0	0	0.15	7.87	< 0.07
	2066		0.09	7.42	< 0.07	0	0	0.13	7.88	< 0.07
	3025		0.09	7.51	< 0.07	0	0	0.15	7.87	0.27
	3066		0.12	7.43	< 0.07	0	0	0.14	8.06	< 0.07
	4001		0.09	7.59	< 0.07	0	0	0.10	8.04	< 0.07
	4026		0.11	7.71	< 0.07	0	0	0.11	8.00	< 0.07
	4067		0.16	7.73	< 0.07	0	0	0.15	7.91	< 0.07
	5001		0.10	7.76	< 0.07	0	0	0.14	7.94	< 0.07
	5024		0.10	7.81	< 0.07	0	0	0.15	7.85	< 0.07
	5066		0.18	7.75	< 0.07	0	0	0.11	7.87	0.84
	6001		0.12	7.74	< 0.07	0	0	0.17	7.81	< 0.07
	6023		0.16	7.84	< 0.07	0	0	0.15	7.80	< 0.07
	6055		0.11	7.77	< 0.07	0	0	0.10	7.89	< 0.07
	7001		0.14	7.80	< 0.07	0	0	0.17	7.86	< 0.07
7039	0.14	7.75	0.53	0	0	0.15	7.83	< 0.07		
8016	0.14	7.74	< 0.07	0	0	0.15	7.82	< 0.07		
W23	G023	23/03/2026	0.12	7.37	< 0.07	0	0	0.16	7.94	1.28
	1031		0.10	7.32	< 0.07	0	0	0.18	7.78	< 0.07
	1052		0.32	7.37	< 0.07	0	0	0.09	7.87	< 0.07
	2031		0.16	7.40	< 0.07	0	0	0.14	7.85	< 0.07
	2056		0.12	7.50	< 0.07	0	0	0.09	7.86	< 0.07
	3031		0.11	7.59	< 0.07	0	0	0.10	7.83	< 0.07
	3056		0.10	7.60	< 0.07	0	0	0.09	7.81	< 0.07
	4031		0.47	7.58	< 0.07	0	0	0.15	7.77	< 0.07
4056	0.09	7.54	< 0.07	0	0	0.08	7.72	< 0.07		
W31	G043	30/03/2026	0.10	7.35	< 0.07	0	0	0.12	7.48	0.14
	G053		0.10	7.44	< 0.07	0	0	0.17	7.58	0.38
	1019		0.12	7.44	< 0.07	0	0	0.08	7.60	0.10
	1063		0.09	7.49	< 0.07	0	0	0.14	7.60	0.13
	2019		0.14	7.52	< 0.07	0	0	0.15	7.63	< 0.07
	2063		0.14	7.56	< 0.07	0	0	0.18	7.67	< 0.07
	3019		0.11	7.52	< 0.07	0	0	0.13	7.61	< 0.07
	3063		0.13	7.51	< 0.07	0	0	0.10	7.65	< 0.07
	4019		0.18	7.44	0.11	0	0	0.20	7.51	0.16
	4063		0.12	7.42	< 0.07	0	0	0.12	7.55	< 0.07
	5019		0.13	7.46	0.13	0	0	0.22	7.49	< 0.07
	5063		0.10	7.47	< 0.07	0	0	0.14	7.50	< 0.07
	6019		0.14	7.49	< 0.07	0	0	0.12	7.52	< 0.07
	6063		0.12	7.48	< 0.07	0	0	0.13	7.50	0.12
7019	0.18	7.31	< 0.07	0	0	0.19	7.39	< 0.07		

Reference standard: Instruções sobre escolha e instalação de dispensadores de água por ligação directa, Environmental Protection Bureau, Government of Macao, S.A.R.  
 Turbidity: ≤ 0.5NTU; pH value: 6.00 - 8.50; Traceable metal of Lead: ≤ 0.01mg/L (10µg/L); Coliform bacteria: Not detected; Escherichia coli: Not detected